

February 5, 2010

## GRAD NIGHT FIRE PREVENTION GUIDELINES

- Fire Extinguisher Do **NOT** block or cover fire extinguishers.
- Exits Do **NOT** cover "EXIT" signs, or **BLOCK** "EXIT" doors.  
If there is an "EXIT" sign above the door, the doorway is a required exit. Exit doors may be decorated. However, the "EXIT" door shall remain recognizable as an exit.
- Fire Alarm Do **NOT** cover pull stations.  
  
The fire alarm system at 2121 Calaveras Avenue, Emerson Jr. High School is monitored. This means when a pull station is pulled, Simplex Monitoring Company notifies Davis Dispatch.
- Fire **NO** open flame devices are permitted at any time.
- Flame-retardant Material Flame-retardant material shall be UL approved for the specific material it is protecting. Flame retardant liquid shall not be a home made.
- Paper and Cloth Decorations Only flame-retardant material approved by UL shall be applied to all decorations exposed to open air on two sides. Flame-retardant material need not be applied to table cloths or decoration taped or stapled to a wall or flat surfaces.
- Electrical Approved extension cords may be used. An approved extension cord has one plug and one receptacle. Extension cords shall **NOT** be run in series with any other extension cords, power strips or multi-plug adapters.  
  
Power strips with a breaker fuse built in may be used. The power strip shall be plugged directly in to the wall outlet; no exceptions.  
  
Multi-plug adapters without a fuse or circuit breaker shall **NOT** be used.  
  
Decorative lighting used in series shall be connected together per manufacture specifications. *per manufacture*
- Tents Davis Fire Department shall approve all tent structures.

## **Fire Equipment Stores that carry fire retardants**

River City Fire Equipment Co., Inc.  
2419 Sellers Way  
West Sacramento, CA 95798  
800-223-1995

Sacramento Fire Extinguisher Company  
4260 – 24<sup>th</sup> Street  
Sacramento, CA  
(916) 456-1331

Sentinel Fire Protection  
5702 Broadway  
Sacramento, CA 95820  
(916) 455-5630

Solon Fire Control  
3190 Luyung Drive  
Rancho Cordova, CA 95742  
(916) 852-4130

### **Manufactures Direct Sales**

Flamort Fire Retardant  
P.O. Box 1971  
San Leandro, CA 94577  
(510) 357-9494

J:\FIRE\Fire Prevention\Administration\other\Fire Prevention Guidelines,  
Gradninght.doc