

GRAD NIGHT FIRE PREVENTION GUIDELINES

| | |
|-----------------------------|--|
| Fire Extinguisher | Do NOT block or cover fire extinguishers. |
| Exits | <p>Do NOT cover "EXIT" signs, or BLOCK "EXIT" doors.</p> <p>If there is an "EXIT" sign above the door, the doorway is a required exit. Exit doors may be decorated. However, the "EXIT" door shall remain recognizable as an exit.</p> |
| Fire Alarm | <p>Do NOT cover pull stations.</p> <p>The fire alarm system at 2121 Calaveras Avenue, Emerson Jr. High School is monitored. This means when a pull station is pulled, Simplex Monitoring Company notifies Davis Dispatch.</p> |
| Fire | NO open flame devices are permitted at any time. |
| Flame-retardant Material | Flame-retardant material shall be UL approved for the specific material it is protecting. Flame retardant liquid shall not be a home made. |
| Paper and Cloth Decorations | Only flame-retardant material approved by UL shall be applied to all decorations exposed to open air on two sides. Flame-retardant material need not be applied to table cloths or decoration taped or stapled to a wall or flat surfaces. |
| Electrical | <p>Approved extension cords may be used. An approved extension cord has one plug and one receptacle. Extension cords shall NOT be run in series with any other extension cords, power strips or multi-plug adapters.</p> <p>Power strips with a breaker fuse built in may be used. The power strip shall be plugged directly in to the wall outlet; no exceptions.</p> <p>Multi-plug adapters without a fuse or circuit breaker shall NOT be used.</p> <p>Decorative lighting used in series shall be connected together per manufacturer specifications</p> |